

Govt. of West Bengal  
Public Health Engineering  
GRIPS eChallan



192026270124470528

GRN Details

|                   |                     |                     |                         |
|-------------------|---------------------|---------------------|-------------------------|
| GRN:              | 192026270124470528  | Payment Mode:       | SBI Epay                |
| GRN Date:         | 29/06/2026 07:38:58 | Bank/Gateway:       | SBIPay Payment Gateway  |
| BRN :             | 9009921383827       | BRN Date:           | 29/06/2026 07:39:17     |
| Gateway Ref ID:   | 125462243891        | Method:             | State Bank of India UPI |
| GRIPS Payment ID: | 290620262012447051  | Payment Init. Date: | 29/06/2026 07:38:58     |
| Payment Status:   | Successful          | Payment Ref. No:    | BRP/REF/026             |

[REF No]

Depositor Details

|                           |                                                                                       |
|---------------------------|---------------------------------------------------------------------------------------|
| Depositor's Name:         | Principal Of Vivekananda Mission School                                               |
| Address:                  | Vivekananda Mission School,Khasmallik Baruipur,South 24 Parganas, West Bengal, 700145 |
| Mobile:                   | 9831347022                                                                            |
| Depositor Status:         | Depositor                                                                             |
| R.E.F. No:                | BRP/REF/026                                                                           |
| Name:                     | Principal Of Vivekananda Mission School                                               |
| Address:                  | Khasmallik,Baruipur,24 Pgs.(S)                                                        |
| Period From (dd/mm/yyyy): | 23/06/2026                                                                            |
| Period To (dd/mm/yyyy):   | 29/06/2026                                                                            |
| Remarks:                  | Water Test                                                                            |

Payment Details

| Sl. No. | Payment Ref No | Head of A/C<br>Description                                                                        | Head of A/C        | Amount (₹) |
|---------|----------------|---------------------------------------------------------------------------------------------------|--------------------|------------|
| 1       | BRP/REF/026    | Collection of fees earned through testing of Private Water Samples in PHE Department Laboratories | 0215-01-104-002-27 | 1400       |
| Total   |                |                                                                                                   |                    | 1400       |

IN WORDS: ONE THOUSAND FOUR HUNDRED ONLY.

**Government of West Bengal**  
**Baruipur Water Treatment Plant Sub District Laboratory**  
**Public Health Engineering Directorate**  
**Begampur Boosting Station-I**  
**Baruipur, South-24pgs.**

**DEEP SUB MARSHAL'S WATER ANALYSIS REPORT OF**  
**"VIVEKANANDA MISSION SCHOOL".**

**G.P.-Hariharpur, Vill.-Khasmallik, Block-Baruipur, 24 Pgs.(S),Kolkata-700145**

|                                  |                                                                                                                                                        |                            |                          |
|----------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------|--------------------------|
| <b>REPORT NO.</b>                | BWTL/S/M/June/OS/09/26-27                                                                                                                              | <b>DATE</b>                | 25/06/2026               |
| <b>ON THE REFERENCE MEMO NO.</b> | BRP/REF/026 Dt. 23/06/2026 of Principal of Vivekananda Mission School,Baruipur                                                                         | <b>SOURCE</b>              | Tap Water                |
|                                  |                                                                                                                                                        | <b>DEPTH</b>               | U/K                      |
| <b>SAMPLE NO.</b>                | Baruipur/S/M/02/24/06/26                                                                                                                               | <b>DATE OF COLLECTION</b>  | 24/06/2026               |
| <b>ADDRESS</b><br><b>G.P.S.</b>  | At the Campus of Vivekananda Mission School. G.P.-Hariharpur, Vill.-Khasmallik, Hab.-Jogi Battala, Block-Baruipur, Kolkata-700145<br>22.3800 / 88.4220 | <b>PERIOD OF TESTING</b>   | 24/06/2026<br>25/06/2026 |
|                                  |                                                                                                                                                        | <b>SAMPLE COLLECTED BY</b> | Baruipur WTP SD Lab.     |

**Water Testings Result (Chemical & Physical)**

| PARAMETERS                                      | RESULT | As per IS: 10500:2012 |                                                       |
|-------------------------------------------------|--------|-----------------------|-------------------------------------------------------|
|                                                 |        | Desirable Limit       | Permissible Limit<br>(in absence of alternate source) |
| pH Value                                        | 7.55   | 6.5 - 8.5             | No relaxation                                         |
| Turbidity,NTU,Max                               | 1.75   | 1 NTU                 | 5 NTU                                                 |
| Total Dissolved Solid, mg/l,Max                 | 601    | 500 mg/l              | 2000 mg/l                                             |
| Total Hardness (as CaCO <sub>3</sub> ),Mg/l,Max | 329    | 200 mg/l              | 600 mg/l                                              |
| Iron (as Fe),Mg/l,Max                           | 0.07   | 0.3mg/l               | 1mg/l                                                 |
| Chloride (as Cl), Mg/l,Max                      | 75     | 250 mg/l              | 1000 mg/l                                             |
| Fluoride (as F),Mg/l,Max                        | 0.07   | 1.00 mg/l             | 1.50 mg/l                                             |
| Total Arsenic (as As),Mg/l,Max                  | <0.01  | 0.01mg/l              | 0.01mg/l                                              |
| Manganese (as Mn),Mg/l,Max                      | 0.03   | 0.1mg/l               | 0.3mg/l                                               |

**Bacteriological Quality of Drinking Water**

| ORGANISMS                | RESULT<br>(in CFU- Colony Forming Unit) | As per IS: 10500:2012                        |                                                          |
|--------------------------|-----------------------------------------|----------------------------------------------|----------------------------------------------------------|
|                          |                                         | Requirements                                 | Permissible limit<br>(in absence of an alternate source) |
| <b>Total Coliform*</b>   | 2 C.F.U.                                | Shall not be detectable in any 100 ml sample | No relaxation                                            |
| <b>Faecal coliform *</b> | Not detect in 100 ml sample             | Shall not be detectable in any 100 ml sample | No relaxation                                            |

\* Procedure – Membrane Filter Technique

Chemist/Bacteriologist  
Baruipur WTP Lab.  
P.H.E.Dte

Junior Engineer  
Baruipur Sub Division  
P.H.E.Dte  
Baruipur Sub-Division,  
Under South 24 Pgs. W/S Divn.  
P.H.E.Dte Govt of W.B.

Assistant Engineer  
Baruipur Sub Division  
P.H.E.Dte  
Baruipur Sub-Division,  
Under South 24 Pgs. W/S Divn.  
P.H.E.Dte Govt of W.B.



**Government of West Bengal**  
**Baruipur Water Treatment Plant Sub District Laboratory**  
**Public Health Engineering Directorate**  
**Begampur Boosting Station-I**  
**Baruipur, South-24pgs.**

**WATER FILTRATION UNIT'S WATER ANALYSIS REPORT OF**  
**"VIVEKANANDA MISSION SCHOOL".**  
**G.P.-Hariharpur, Vill.-Khasmallik, Block-Baruipur, 24 Pgs.(S),Kolkata-700145**

|                           |                                                                                                                                             |                     |                          |
|---------------------------|---------------------------------------------------------------------------------------------------------------------------------------------|---------------------|--------------------------|
| REPORT NO.                | BWTL/W/F/U/June/OS/08/26-27                                                                                                                 | DATE                | 25/06/2026               |
| ON THE REFERENCE MEMO NO. | BRP/REF/026 Dt. 23/06/2026 of Principal of Vivekananda Mission School, Baruipur                                                             | SOURCE              | Water Filter             |
|                           |                                                                                                                                             | DEPTH               | N/A                      |
| SAMPLE NO.                | Baruipur/W/F/U/01/24/06/26                                                                                                                  | DATE OF COLLECTION  | 24/06/2026               |
| ADDRESS<br>G.P.S.         | At Vivekananda Mission School.<br>G.P.-Hariharpur, Vill.-Khasmallik, Hab.-Jogi Battala, Block-Baruipur, Kolkata-700145<br>22.3796 / 88.4221 | PERIOD OF TESTING   | 24/06/2026<br>25/06/2026 |
|                           |                                                                                                                                             | SAMPLE COLLECTED BY | Baruipur WTP SD Lab.     |

**Water Testings Result (Chemical & Physical)**

| PARAMETERS                                        | RESULT | As per IS: 10500:2012 |                                                       |
|---------------------------------------------------|--------|-----------------------|-------------------------------------------------------|
|                                                   |        | Desirable Limit       | Permissible Limit<br>(in absence of alternate source) |
| pH Value                                          | 7.45   | 6.5 - 8.5             | No relaxation                                         |
| Turbidity, NTU, Max                               | 0.45   | 1 NTU                 | 5 NTU                                                 |
| Total Dissolved Solid, mg/l, Max                  | 597    | 500 mg/l              | 2000 mg/l                                             |
| Total Hardness (as CaCO <sub>3</sub> ), Mg/l, Max | 329    | 200 mg/l              | 600 mg/l                                              |
| Iron (as Fe), Mg/l, Max                           | 0.05   | 0.3mg/l               | 1mg/l                                                 |
| Chloride (as Cl), Mg/l, Max                       | 75     | 250 mg/l              | 1000 mg/l                                             |
| Fluoride (as F), Mg/l, Max                        | 0.08   | 1.00 mg/l             | 1.50 mg/l                                             |
| Total Arsenic (as As), Mg/l, Max                  | <0.01  | 0.01mg/l              | 0.01mg/l                                              |
| Manganese (as Mn), Mg/l, Max                      | 0.01   | 0.1mg/l               | 0.3mg/l                                               |

**Bacteriological Quality of Drinking Water**

| ORGANISMS         | RESULT<br>(in CFU- Colony Forming Unit) | As per IS: 10500:2012                        |                                                          |
|-------------------|-----------------------------------------|----------------------------------------------|----------------------------------------------------------|
|                   |                                         | Requirements                                 | Permissible limit<br>(in absence of an alternate source) |
| Total Coliform*   | Not detect in 100 ml sample             | Shall not be detectable in any 100 ml sample | No relaxation                                            |
| Faecal coliform * | Not detect in 100 ml sample             | Shall not be detectable in any 100 ml sample | No relaxation                                            |

\* Procedure - Membrane Filter Technique

*[Signature]*  
 25/06/26  
 Chemist/Bacteriologist  
 Baruipur WTP Lab.  
 P.H.E.Dte

*[Signature]*  
 Junior Engineer  
 Baruipur Sub Division  
 P.H.E. Dte  
 Baruipur Sub-Division,  
 Under South 24 Pgs. W/S Divn.  
 P.H.E. Dte Govt. of W.B.

*[Signature]*  
 Assistant Engineer  
 Baruipur Sub Division  
 P.H.E. Dte  
 Baruipur Sub-Division,  
 Under South 24 Pgs. W/S Divn.  
 P.H.E. Dte Govt. of W.B.

**Annexure C**

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**


**Report No.-** BWTL/W/F/U/June/OS/08/26-27

**Dated.-**25/06/2026

It is certified that an inspection team headed by Arijit Dasgupta (Bacteriologist) & Rupak Haldar (Sample Collector Cum Lab. Assistant) from Baruipur Water Treatment Plant SD Laboratory PHED inspected the **Vivekananda Mission School**, Vill.- Khasmallik, G.P.- Hariharpur, Post.- Baruipur, P.S.- Baruipur, South 24 Parganas, Kolkata- 700145 on 24/06/2026 and on the basis of Water Test Report bearing no. BWTL/W/F/U/June/OS/08/26-27 dated 25/06/2026 of Baruipur Water Treatment Plant SD Laboratory, PHED Dte. Certified that the **Vivekananda Mission School**, Vill.- Khasmallik, G.P.- Hariharpur, Post.- Baruipur, P.S.- Baruipur, South 24 Parganas, Kolkata- 700145 have safe drinking water facilities for the student and members of staff of the institution. School is also maintaining the Hygienic sanitation condition in the school building & the campus as per norms prescribed by the central/State/U.T. Govt.

This certificate is valid till 24/06/2027.

To  
Vivekananda Mission School  
Khasmallik, Hariharpur, Baruipur,  
South 24 Parganas,  
Pin-700145

  
Signature with seal  
Name- Vivek Jha  
Designation- Assistant Engineer  
Baruipur Sub Division  
Public Health Engineering Dte.  
Name & Address of the office/Department

Assistant Engineer  
Baruipur Sub-Division,  
Under South 24 Prgns. W/S Divn  
PHE Dte Govt of W.P

**Note.-the certificate is to be issued by authorized officer/PHED Lab./Local bodies.**