



Government Of West Bengal
Office Of The Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata - 16

Memo no.:IND/WB/FES/20182019/1/23555

Date: 31-08-2023

From:
Director
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To: VIVEKANANDA MISSION SCHOOL
MOUZA - KHASMALICK, J.L. NO.- 35 AND KHATIAN NO.-2203, P.O.- BARUIPUR, HARIHARPUR GRAM
PANCHAYAT, DIST.- SOUTH 24 PARGANAS, PIN - 700144

Sub: Part Fire Safety Certificate in favour of an existing G+III storied (Partly) under group of Educational building in the name & style of "VIVEKANANDA MISSION SCHOOL" at the premises no.- Mouza-Khasmallick, J.L.no.- 35 and Khatian no.- 2203, P.O.- Baruipur, Grampanchayat Hariharpur (Baruipur Block), Dist.- South 24 Parganas.

This is in reference to your application no. 0125189231200143 dated 20-07-2023 regarding the Part Fire Safety Certificate in favour of an existing G+III storied (Partly) under group of Educational building in the name & style of "VIVEKANANDA MISSION SCHOOL" at the premises no.- Mouza-Khasmallick, J.L.no.- 35 and Khatian no.- 2203, P.O.- Baruipur, Grampanchayat Hariharpur (Baruipur Block), Dist.- South 24 Parganas.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

- 1.No deviation will be allowed without prior permission of this directorate and no parking will be allowed on the Drive way.
- 2.The Interior finish decoration of building shall be made with low flame spread material confirming to the I.S. Specification.
- 3.To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
- 4.Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.
- 5.The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable places of the building.
- 6.The employees and security staff teaching and non-teaching staffs shall have to be conversant with installed fire fighting equipments of the building and to operate in the event of fire and testing.
7. Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the

8. switch gear, main & meter room shall be protected with CO2 or DCP Fire extinguishers confirming I.S. specifications.
9. First Aid fire fighting system shall be provided as per I.S. specifications.
10. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the building to keep them in perfectly good working condition at all the times.
11. If required the old electrical lines shall have to be replaced with new lines. The cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
12. Periodical flashing of water in the pipe line shall be made to maintain the efficient working performance of above mentioned system.

This Fire Safety Certificate is valid for three (03) years from the date of issue of this certificate and has to be renewed within validity period.

The certificate has to be obtained from the Director General, West Bengal Fire & Emergency Services regarding performance of all the Fire Safety arrangements and installations of the building.

Signature Not Verified
Digitally signed by ABHIJIT
PANDEY
Date: 2023.08.29 15:30:43 IST

Director
West Bengal Fire & Emergency Services